

CERTIFICATE OF COMPLIANCE



Iris US

Marmi Collection

Restrictions:

UL 2818 - 2013 Standard for Chemical Emissions for Building Materials, Finishes and Furnishings

11732-410

Certificate Number

15 Apr 2009 - 15 Apr 2023

Certificate Period

Certified

Status

Flooring is determined compliant in accordance with an Office environment with an air change of 0.68 hr^{-1} and a loading of 11.10 m^2 .

Products tested in accordance with UL 2821 test method to show compliance to emission limits in UL 2818, Section 7.1.



UL investigated representative samples of the identified Product(s) to the identified Standard(s) or other requirements in accordance with the agreements and any applicable program service terms in place between UL and the Certificate Holder (collectively "Agreement"). The Certificate Holder is authorized to use the UL Mark for the identified Product(s) manufactured at the production site(s) covered by the UL Test Report, in accordance with the terms of the Agreement. This Certificate is valid for the identified