

# CERTIFICATE OF COMPLIANCE



## Iris US ZENIT COLLECTION

269302-410  
Certificate Number

26 May 2022 - 15 Apr 2023  
Certificate Period

Certified  
Status

UL 2818 - 2013 Standard for Chemical Emissions for Building Materials, Finishes and Furnishings

Flooring is determined compliant in accordance with an Office environment with an air change of  $0.68 \text{ hr}^{-1}$  and a loading of  $11.10 \text{ m}^2$ .  
Products tested in accordance with UL 2821 test method to show compliance to emission limits in UL 2818, Section 7.1.



UL investigated representative samples of the identified Product(s) to the identified Standard(s) or other requirements in accordance with the agreements and any applicable program service terms in place between UL and the Certificate Holder (collectively "Agreement"). The Certificate Holder is authorized to use the UL Mark for the identified Product(s) manufactured at the production site(s) covered by the UL Test Report, in accordance with the terms of the Agreement. This Certificate is valid for the identified